

No CFC or H-CFC Use Policy

The Bristol Warren Regional School District bans the use of CFC or HCFC-based refrigerants in building heating, ventilating, air conditioning and refrigeration (HVAC & R) systems, as well as the installation of CFC or HCFC-based refrigerants in heating, ventilating, air conditioning and refrigeration (HVAC & R) systems in all newly constructed buildings district-wide.

For all renovation projects, replacement of any equipment that utilizes CFC or HCFC-based refrigerants and is over ten (10) years old will be required.

In addition, the Superintendent of Schools shall designate personnel in the Bristol Warren Regional School District to develop and implement a plan to phase out the use of such refrigerants in all existing equipment within five years.

ADOPTED: April 25, 2011

Legal Ref.: RI Department of Education Necessity of School Construction

Bristol Warren Regional School District, Bristol, Rhode Island